TEST REPORT

(Electronic version)

扫码下载报告

VERIFICATION WEBSITE: www.gttc.net.cn

VERIFICATION CODE: ICOQ-6406-54

No:200163055 ISSUE DATE:2020-06-04

APPLICANT: HUNAN MINGYU NONWOVENS CO.,LTD
ADDRESS: NO.333 DESHAN AVENUE ,CHANGDE ECONOMIC AND TECHNOLOGY DEVELOP -MENT DISTRICT,HUNAN PROVINCE CHINA

INFORMATION CONFIRMED BY APPLICANT:

MELT-BLOW BFE99

QUANTITY: 1 PIECES

STYLE NO.: NO#2

COLOUR: WHITE

SIZE: 100cm×150cm

WEIGHT: 22g/m²

MANUFACTURE'S NAME: HUNAN MINGYU NONWOVENS CO.,LTD

DATE RECEIVED/DATE TEST STARTED: 2020-06-04

CONCLUSION:

BACTERIAL FILTRATION EFFICIENCY	M
PARTICLE FILTRATION EFFICIENCY	M
AIRFLOW RESISTANCE	---

NOTE: "M" -MEET THE STANDARD'S REQUIREMENT "F" -FAIL TO MEET THE STANDARD'S REQUIREMENT
"---" -NO COMMENT

REMARK:
TEST MATERIAL,TESTED AND JUDGED BY YY 0469-2011 AS PER CLIENT'S REQUIREMENT.
THIS REPORT IS THE ENGLISH TRANSLATION VERSION OF THE REPORT 200049159.
ALL THE TESTED ITEMS ARE TESTED UNDER THE STANDARD CONDITION (EXCEPT FOR INDICATION).
COPIES OF THE REPORT ARE VALID ONLY RE-STAMPED.
THE EXPERIMENT WAS CARRIED OUT AT No.1, ZHUJIANG ROAD, PANYU DISTRICT, GUANGZHOU, GUANGDONG, P.R.CHINA.

APPROVED BY: 马楠

Nan Ma ENGINEER

广州检验检测认证集团有限公司 检验检测专用章 (GF2)

总部: 广州市番禺区珠江路1号
花都实验室: 广州市花都区狮岭镇旗岭河滨西路1号
电话:020-61994598/61994599
电话:020-37721161

TEST REPORT

(Electronic version)

No:200163055



广州检验检测认证集团有限公司 检验检测专用章 (GF2)

总部： 广州市番禺区珠江路1号
花都实验室： 广州市花都区狮岭镇旗岭河滨西路1号
电话:020-61994598/61994599
电话:020-37721161

TEST REPORT

(Electronic version)

No:200163055

BACTERIAL FILTRATION EFFICIENCY(%)

(YY 0469-2011 ANNEX B, TEST BACTERIA: STAPHYLOCOCCUS AUREUS ATCC 6538, TEST AREA: 40cm^2 , FLOW RATE: 28.3L/min, MEAN PARTICLE SIZE: 3.0μm, RESULT OF THE POSITIVE CONTROL: 1.9×10^3 CFU , RESULT OF THE NEGATIVE CONTROL: ＜1CFU)

		REQUIREMENT
BFE_1	98.8	≥95
BFE_2	98.5	(YY 0469-2011)
BFE_3	98.3	

PARTICLE FILTRATION EFFICIENCY(%)

(YY 0469-2011 5.6.2, AIR FLOW: 30L/min, AEROSOL: NaCl, AEROSOL CONCENTRATION: 15mg/m^3 , TEMP: 23.1℃, RH: 36.0%)

	REQUIREMENT
MINIMUM 88.0	≥30 (YY 0469-2011)

AIRFLOW RESISTANCE(Pa)

(YY 0469-2011 5.6.2, AIR FLOW: 30L/min, AEROSOL: NaCl, AEROSOL CONCENTRATION: 15mg/m^3 , TEMP: 23.1℃, RH: 36.0%)

MAXIMUM 31.4

广州检验检测认证集团有限公司 检验检测专用章 (GF2)

———End of Report———

总部： 广州市番禺区珠江路1号
花都实验室： 广州市花都区狮岭镇旗岭河滨西路1号
电话:020-61994598/61994599
电话:020-37721161